

WATER COOLING AND COOLING TOWERS

251

rapidly the vapour contents and the corresponding amount of heat increase with the temperature.



Fig. 29.—Heat and Vapour Contents in i lb. Air at Atmospheric Pressure

Suppose the saturated air entering a cooling tower at 60° F. leaves the tower saturated at 90° F., then the amount of vapour absorbed is

$$0.031 - 0.011 = 0.02 \text{ lb. per pound air,}$$

and the absorption of heat is

$$48 - 18 = 30 \text{ B.Th.U. per pound air.}$$

Under normal conditions of operation, however, the air entering and